Energy performance certificate (EPC)

S7 Wingfield Way
BEVERLEY
HU17 8XE

Energy rating

Valid until: 14 September 2032

Certificate 2120-8401-0020-1200number: 5595

Property type Detached house

Total floor area 117 square metres

Rules on letting this property


Properties can be let if they have an energy rating from A to E.

You can read <u>guidance</u> for <u>landlords</u> on the <u>regulations</u> and <u>exemptions</u> (https://www.gov.uk/guidance/domestic-private-rented-property-minimum-energy-efficiency-standard-landlord-guidance).

Energy rating and score

This property's energy rating is C. It has the potential to be B.

See how to improve this property's energy efficiency.



The graph shows this property's current and potential energy rating.

Properties get a rating from A (best) to G (worst) and a score. The better the rating and score, the lower your energy bills are likely to be.

For properties in England and Wales:

the average energy rating is D the average energy score is 60

Breakdown of property's energy performance

Features in this property

Features get a rating from very good to very poor, based on how energy efficient they are. Ratings are not based on how well features work or their condition.

Assumed ratings are based on the property's age and type. They are used for features the assessor could not inspect.

Feature	Description	Rating
Wall	Cavity wall, as built, insulated (assumed)	Good
Roof	Pitched, 400+ mm loft insulation	Very good
Roof	Pitched, insulated at rafters	Good
Window	Fully double glazed	Good
Main heating	Boiler and radiators, mains gas	Good
Main heating control	Programmer, room thermostat and TRVs	Good
Hot water	From main system	Good
Lighting	Low energy lighting in all fixed outlets	Very good
Floor	Solid, insulated (assumed)	N/A
Floor	To external air, insulated (assumed)	N/A
Secondary heating	None	N/A

Primary energy use

The primary energy use for this property per year is 147 kilowatt hours per square metre (kWh/m2).

How this affects your energy bills

An average household would need to spend £683 per year on heating, hot water and lighting in this property. These costs usually make up the majority of your energy bills.

You could **save £30 per year** if you complete the suggested steps for improving this property's energy rating.

This is **based on average costs in 2022** when this EPC was created. People living at the property may use different amounts of energy for heating, hot water and lighting.

Heating this property

Estimated energy needed in this property is:

- 8,782 kWh per year for heating
- 2,284 kWh per year for hot water

Impact on the environment

This property's environmental impact rating is C. It has the potential to be B.

Properties get a rating from A (best) to G (worst) on how much carbon dioxide (CO2) they produce each year.

Carbon emissions

An average household produces

6 tonnes of CO2

This property produces 3.0 tonnes of CO2

This property's 1.9 tonnes of CO2

potential production

You could improve this property's CO2 emissions by making the suggested changes. This will help to protect the environment.

These ratings are based on assumptions about average occupancy and energy use. People living at the property may use different amounts of energy.

Changes you could make

Step	Typical installation cost	Typical yearly saving
1. Solar water heating	£4,000 - £6,000	£30
2. Solar photovoltaic panels	£3,500 - £5,500	£347

Help paying for energy improvements

You might be able to get a grant from the <u>Boiler Upgrade Scheme (https://www.gov.uk/apply-boiler-upgrade-scheme)</u>. This will help you buy a more efficient, low carbon heating system for this property.

More ways to save energy

Find ways to save energy in your home by visiting www.gov.uk/improve-energy-efficiency

Who to contact about this certificate

Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name	Finlay Easey
Telephone	07927176316
Email	finlayepc247@gmail.com

Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme	Quidos Limited	
Assessor's ID	QUID208576	
Telephone	01225 667 570	
Email	info@quidos.co.uk	

About this assessment

Assessor's declaration	No related party	
Date of assessment	15 September 2022	
Date of certificate	15 September 2022	
Type of assessment	RdSAP	