

# Energy performance certificate (EPC)

|  |                           |   |
|--|---------------------------|---|
| Fern Cottage<br>Silverwell<br>Blackwater<br>TRURO<br>TR4 8JH | Energy rating<br><b>E</b> | Valid until: <b>9 October 2031</b><br><br>Certificate number: <b>0310-2033-0010-2929-7961</b> |
|--|---------------------------|---|

Property type

Detached house

Total floor area

133 square metres

## Rules on letting this property

Properties can be rented if they have an energy rating from A to E.

If the property is rated F or G, it cannot be let, unless an exemption has been registered. You can read [guidance for landlords on the regulations and exemptions \(https://www.gov.uk/guidance/domestic-private-rented-property-minimum-energy-efficiency-standard-landlord-guidance\)](https://www.gov.uk/guidance/domestic-private-rented-property-minimum-energy-efficiency-standard-landlord-guidance).

## Energy efficiency rating for this property

This property's current energy rating is E. It has the potential to be B.

[See how to improve this property's energy performance.](#)

| Score | Energy rating | Current | Potential |
|-------|---------------|---------|-----------|
| 92+   | A             |         |           |
| 81-91 | B             |         | 90   B    |
| 69-80 | C             |         |           |
| 55-68 | D             |         |           |
| 39-54 | E             | 46   E  |           |
| 21-38 | F             |         |           |
| 1-20  | G             |         |           |

The graph shows this property's current and potential energy efficiency.

Properties are given a rating from A (most efficient) to G (least efficient).

Properties are also given a score. The higher the number the lower your fuel bills are likely to be.

For properties in England and Wales:

the average energy rating is D  
the average energy score is 60

## Breakdown of property's energy performance

This section shows the energy performance for features of this property. The assessment does not consider the condition of a feature and how well it is working.

Each feature is assessed as one of the following:

- very good (most efficient)
- good
- average
- poor
- very poor (least efficient)

When the description says "assumed", it means that the feature could not be inspected and an assumption has been made based on the property's age and type.

| Feature              | Description   | Rating    |
|----------------------|---|-----------|
| Wall                 | Granite or whinstone, as built, no insulation (assumed) | Very poor |
| Wall                 | Cavity wall, as built, no insulation (assumed)          | Poor      |
| Wall                 | Cavity wall, filled cavity                              | Average   |
| Roof                 | Pitched, 270 mm loft insulation                         | Good      |
| Roof                 | Flat, limited insulation (assumed)                      | Very poor |
| Roof                 | Pitched, 150 mm loft insulation                         | Good      |
| Window               | Fully double glazed                                     | Average   |
| Main heating         | Boiler and radiators, oil                               | Average   |
| Main heating control | Programmer, room thermostat and TRVs                    | Good      |
| Hot water            | From main system  | Average   |
| Lighting             | Low energy lighting in 47% of fixed outlets             | Good      |
| Floor                | Solid, no insulation (assumed)                          | N/A       |
| Secondary heating    | Room heaters, wood logs                                 | N/A       |

## Low and zero carbon energy sources

Low and zero carbon energy sources release very little or no CO<sub>2</sub>. Installing these sources may help reduce energy bills as well as cutting carbon emissions. The following low or zero carbon energy sources are installed in this property:

- Biomass secondary heating

## Primary energy use

The primary energy use for this property per year is 224 kilowatt hours per square metre (kWh/m<sup>2</sup>).

## Additional information

Additional information about this property:

- Cavity fill is recommended
- Stone walls present, not insulated
- Dwelling may be exposed to wind-driven rain

## Environmental impact of this property

One of the biggest contributors to climate change is carbon dioxide (CO<sub>2</sub>). The energy used for heating, lighting and power in our homes produces over a quarter of the UK's CO<sub>2</sub> emissions.

An average household produces 6 tonnes of CO<sub>2</sub>

This property produces 7.0 tonnes of CO<sub>2</sub>

This property's potential production 1.4 tonnes of CO<sub>2</sub>

By making the [recommended changes](#), you could reduce this property's CO<sub>2</sub> emissions by 5.6 tonnes per year. This will help to protect the environment.

Environmental impact ratings are based on assumptions about average occupancy and energy use. They may not reflect how energy is consumed by the people living at the property.

## How to improve this property's energy performance

Making any of the recommended changes will improve this property's energy efficiency.

If you make all of the recommended changes, this will improve the property's energy rating and score from E (46) to B (90).

| Recommendation                             | Typical installation cost | Typical yearly saving |
|--|---------------------------|-----------------------|
| 1. Flat roof or sloping ceiling insulation | £850 - £1,500             | £43                   |
| 2. Cavity wall insulation                  | £500 - £1,500             | £74                   |
| 3. Internal or external wall insulation    | £4,000 - £14,000          | £183                  |
| 4. Floor insulation (solid floor)          | £4,000 - £6,000           | £66                   |
| 5. Low energy lighting                     | £40                       | £46                   |
| 6. Solar water heating                     | £4,000 - £6,000           | £36                   |
| 7. High performance external doors         | £2,000                    | £23                   |
| 8. Solar photovoltaic panels               | £3,500 - £5,500           | £377                  |
| 9. Wind turbine                            | £15,000 - £25,000         | £684                  |

## Paying for energy improvements

[Find energy grants and ways to save energy in your home. \(https://www.gov.uk/improve-energy-efficiency\)](https://www.gov.uk/improve-energy-efficiency)

## Estimated energy use and potential savings

|  |       |
|--|-------|
| Estimated yearly energy cost for this property | £1242 |
|--|-------|

|                  |      |
|------------------|------|
| Potential saving | £473 |
|------------------|------|

The estimated cost shows how much the average household would spend in this property for heating, lighting and hot water. It is not based on how energy is used by the people living at the property.

The estimated saving is based on making all of the recommendations in [how to improve this property's energy performance](#).

For advice on how to reduce your energy bills visit [Simple Energy Advice](#) (<https://www.simpleenergyadvice.org.uk/>).

## Heating use in this property

Heating a property usually makes up the majority of energy costs.

## Estimated energy used to heat this property

|               |                    |
|---------------|--------------------|
| Space heating | 17148 kWh per year |
|---------------|--------------------|

|               |                   |
|---------------|-------------------|
| Water heating | 3779 kWh per year |
|---------------|-------------------|

## Potential energy savings by installing insulation

| Type of insulation | Amount of energy saved |
|--------------------|------------------------|
|--------------------|------------------------|

|                 |                  |
|-----------------|------------------|
| Loft insulation | 136 kWh per year |
|-----------------|------------------|

|                        |                   |
|------------------------|-------------------|
| Cavity wall insulation | 1449 kWh per year |
|------------------------|-------------------|

|                       |                   |
|-----------------------|-------------------|
| Solid wall insulation | 3576 kWh per year |
|-----------------------|-------------------|

You might be able to receive [Renewable Heat Incentive payments](#) (<https://www.gov.uk/domestic-renewable-heat-incentive>). This will help to reduce carbon emissions by replacing your existing heating system with one that generates renewable heat. The estimated energy required for space and water heating will form the basis of the payments.

## Contacting the assessor and accreditation scheme

This EPC was created by a qualified energy assessor.

If you are unhappy about your property's energy assessment or certificate, you can complain to the assessor directly.

If you are still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation schemes are appointed by the government to ensure that assessors are qualified to carry out EPC assessments.

### Assessor contact details

|                 |  |
|-----------------|--|
| Assessor's name | Andrew McCaffrey   |
| Telephone       | 07968563243  |
| Email           | <a href="mailto:andyaltern8@aol.com">andyaltern8@aol.com</a> |

### Accreditation scheme contact details

|                      |  |
|----------------------|--|
| Accreditation scheme | Elmhurst Energy Systems Ltd  |
| Assessor ID          | EES/020327   |
| Telephone            | 01455 883 250  |
| Email                | <a href="mailto:enquiries@elmhurstenergy.co.uk">enquiries@elmhurstenergy.co.uk</a> |

### Assessment details

|                        |                       |
|------------------------|-----------------------|
| Assessor's declaration | No related party      |
| Date of assessment     | 27 September 2021     |
| Date of certificate    | 10 October 2021       |
| Type of assessment     | <a href="#">RdSAP</a> |

---