

Energy performance certificate (EPC)

Stronsay Beacon Crescent Tilford Road Hindhead GU26 6UG	Energy rating D	Valid until: 21 March 2033 Certificate number: 4404-2057-4804-7609-4472
---------------------------------------------------------------------	---------------------------	----------------------------------------------------------------------------

Property type	Offices and Workshop Businesses
Total floor area	393 square metres


Rules on letting this property

Properties can be let if they have an energy rating from A+ to E.

You can read [guidance for landlords on the regulations and exemptions \(https://www.gov.uk/government/publications/non-domestic-private-rented-property-minimum-energy-efficiency-standard-landlord-guidance\)](https://www.gov.uk/government/publications/non-domestic-private-rented-property-minimum-energy-efficiency-standard-landlord-guidance).

Energy rating and score

This property's current energy rating is D.



Properties get a rating from A+ (best) to G (worst) and a score.

The better the rating and score, the lower your property's carbon emissions are likely to be.

How this property compares to others

Properties similar to this one could have ratings:

If newly built

10 A

If typical of the existing stock

41 B

Breakdown of this property's energy performance

Main heating fuel

Grid Supplied Electricity

Building environment	Heating and Natural Ventilation
Assessment level	3
Building emission rate (kgCO₂/m² per year)	35.67
Primary energy use (kWh/m² per year)	371

► [About primary energy use](#)

Recommendation report

Guidance on improving the energy performance of this property can be found in the [recommendation report \(/energy-certificate/1862-5801-4603-6033-7118\)](#).

Who to contact about this certificate

Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name	Tessa Lancaster
Telephone	01252 213456
Email	info@iventinventoryclerks.co.uk

Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme	Stroma Certification Ltd
Assessor's ID	STRO035145
Telephone	0330 124 9660
Email	certification@stroma.com

About this assessment

Employer	iVent Energy Assessor
Employer address	<insert Employer/Trading Address>
Assessor's declaration	The assessor is not related to the owner of the property.
Date of assessment	13 March 2023
Date of certificate	22 March 2023

Other certificates for this property

If you are aware of previous certificates for this property and they are not listed here, please contact us at djuh.digital-services@levellingup.gov.uk or call our helpdesk on 020 3829 0748 (Monday to Friday, 9am to 5pm).

Certificate number	0650-0831-1180-0725-4002 (/energy-certificate/0650-0831-1180-0725-4002)
Expired on	25 May 2019

[Help](#) (/help) [Accessibility](#) (/accessibility-statement) [Cookies](#) (/cookies)

[Give feedback](https://forms.office.com/e/hUnC3Xq1T4) (https://forms.office.com/e/hUnC3Xq1T4) [Service performance](#) (/service-performance)

OGL

All content is available under the [Open Government Licence v3.0](https://www.nationalarchives.gov.uk/doc/open-government-licence/version/3/) (https://www.nationalarchives.gov.uk/doc/open-government-licence/version/3/), except where otherwise stated



[ght](https://www.nationalarchives.gov.uk/information-management/re-using-public-sector-information/uk-government-licensing-framework/crown-c) (https://www.nationalarchives.gov.uk/information-management/re-using-public-sector-information/uk-government-licensing-framework/crown-c