

# Energy performance certificate (EPC)

|   |                           |   |
|---|---------------------------|---|
| Estate Canteen<br>Netherwood Road<br>ROTHERWAS<br>HR2 6JU | Energy rating<br><b>B</b> | Valid until: <b>17 October 2031</b>                 |
|   |                           | Certificate number: <b>6172-1988-9866-7829-4688</b> |

## Property type

A3/A4/A5 Restaurant and Cafes/Drinking Establishments and Hot Food takeaways

## Total floor area

210 square metres

## Rules on letting this property

Properties can be let if they have an energy rating from A+ to E.

If a property has an energy rating of F or G, the landlord cannot grant a tenancy to new or existing tenants, unless an exemption has been registered.

From 1 April 2023, landlords will not be allowed to continue letting a non-domestic property on an existing lease if that property has an energy rating of F or G.


You can read [guidance for landlords on the regulations and exemptions](https://assets.publishing.service.gov.uk/government/uploads/system/uploads/attachment_data/file/824018/Non-Dom_Private_Rented_Property_Minimum_Standard_-_Landlord_Guidance.pdf) ([https://assets.publishing.service.gov.uk/government/uploads/system/uploads/attachment\\_data/file/824018/Non-Dom\\_Private\\_Rented\\_Property\\_Minimum\\_Standard\\_-\\_Landlord\\_Guidance.pdf](https://assets.publishing.service.gov.uk/government/uploads/system/uploads/attachment_data/file/824018/Non-Dom_Private_Rented_Property_Minimum_Standard_-_Landlord_Guidance.pdf)).

## Energy efficiency rating for this property

This property's current energy rating is B.

Under 0 **A+**

Net zero CO2



41 | B

Properties are given a rating from A+ (most efficient) to G (least efficient).

Properties are also given a score. The larger the number, the more carbon dioxide (CO2) your property is likely to emit.

### How this property compares to others

Properties similar to this one could have ratings:

#### If newly built

29 | B

#### If typical of the existing stock

84 | D

### Breakdown of this property's energy performance

#### Main heating fuel

Natural Gas

#### Building environment

Heating and Natural Ventilation

#### Assessment level

**Building emission rate (kgCO<sub>2</sub>/m<sup>2</sup> per year)**105.06

---

**Primary energy use (kWh/m<sup>2</sup> per year)**606

---

▶ [What is primary energy use?](#)

**Recommendation report**

Guidance on improving the energy performance of this property can be found in the [recommendation report \(/energy-certificate/4374-1317-9595-7528-5103\)](/energy-certificate/4374-1317-9595-7528-5103).

**Contacting the assessor and accreditation scheme**

This EPC was created by a qualified energy assessor.

If you are unhappy about your property's energy assessment or certificate, you can complain to the assessor directly.

If you are still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation schemes are appointed by the government to ensure that assessors are qualified to carry out EPC assessments.

**Assessor contact details****Assessor's name**Stephen Harper

---

**Telephone**01594 810090 07500804620

---

**Email**[forestenergyassessors@talktalk.net](mailto:forestenergyassessors@talktalk.net)

---

**Accreditation scheme contact details****Accreditation scheme**Elmhurst Energy Systems Ltd

---

**Assessor ID**EES/008432

---

**Telephone**

01455 883 250

---

**Email**

[enquiries@elmhurstenergy.co.uk](mailto:enquiries@elmhurstenergy.co.uk)

---

**Assessment details****Employer**

Stephen Harper

---

**Employer address**

1 Rose Cottage, Old Road, Coalway, Coleford, Gloucestershire, GL16 7JN

---

**Assessor's declaration**

The assessor is not related to the owner of the property.

---

**Date of assessment**

15 September 2021

---

**Date of certificate**

18 October 2021

---

**Other certificates for this property**

If you are aware of previous certificates for this property and they are not listed here, please contact us at [mhclg.digital-services@communities.gov.uk](mailto:mhclg.digital-services@communities.gov.uk) or call our helpdesk on 020 3829 0748.

There are no related certificates for this property.