

Energy performance certificate (EPC)

Far Forest Centre
Church Lane
Far Forest
KIDDERMINSTER
DY14 9TP

Energy rating

G

Valid until: 13 May 2036

Certificate number: 5257-1268-2598-7318-0906

Property type	Non-residential Institutions: Community/Day Centre
Total floor area	281 square metres

Rules on letting this property

! You may not be able to let this property.


This property has an energy rating of G. The landlord cannot grant a tenancy to new or existing tenants, unless an exemption has been registered.

From 1 April 2023, landlords will not be allowed to continue letting a non-domestic property on an existing lease if that property has an energy rating of F or G.

Properties can be let if they have an energy rating from A+ to E. The [recommendation report](#) sets out changes you can make to improve the property's rating.

Energy rating and score

This property's energy rating is G.



Properties get a rating from A+ (best) to G (worst) and a score.

The better the rating and score, the lower your property's carbon emissions are likely to be.

How this property compares to others

Properties similar to this one could have ratings:

If newly built	25 A
If typical of the existing stock	99 D

Breakdown of this property’s energy performance

Main heating fuel	Oil
Building environment	Heating and Natural Ventilation
Assessment level	3
Building emission rate (kgCO2/m2 per year)	107.31
Primary energy use (kWh/m2 per year)	482

Recommendation report

Guidance on improving the energy performance of this property can be found in the [recommendation report \(/energy-certificate/0735-5756-5600-8196-2028\)](#).

Who to contact about this certificate

Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name	Mark Hawthorne
Telephone	07793 140 000
Email	mark@hawthorneconsultants.co.uk

Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme	Elmhurst Energy Systems Ltd
Assessor's ID	EES/016736
Telephone	01455 883 250
Email	enquiries@elmhurstenergy.co.uk

About this assessment

Employer	Hawthorne Energy Consultants Limited
Employer address	14 Shaw Avenue, Kidderminster DY10 3YX
Assessor's declaration	The assessor is not related to the owner of the property.
Date of assessment	6 May 2026
Date of certificate	14 May 2026
