
59 square metres

Total floor area




### Rules on letting this property

Properties can be let if they have an energy rating from A+ to E.

### **Energy rating and score**

This property's energy rating is B.



Properties get a rating from A+ (best) to G (worst) and a score.

The better the rating and score, the lower your property's carbon emissions are likely to be.

## How this property compares to others

Properties similar to this one could have ratings:

If newly built	19 A
If typical of the existing stock	57 C

## Breakdown of this property's energy performance

Main heating fuel	Natural Gas
Building environment	Heating and Natural Ventilation
Assessment level	3
Building emission rate (kgCO2/m2 per year)	87.76
Primary energy use (kWh/m2 per year)	513

# **Recommendation report**

Guidance on improving the energy performance of this property can be found in the  $\underline{\text{recommendation report (/energy-certificate/0680-0140-9432-3402-5002)}$ .

#### Who to contact about this certificate

#### Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name J Bailey
Telephone 07714305555

Email james.bailey1@hotmail.co.uk

#### Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme ECMK

 Assessor's ID
 ECMK302755

 Telephone
 0333 123 1418

 Email
 info@ecmk.co.uk

About this assessment

Employer Local Property Reports- Tel: 07714305555

Employer address 20 Botley Road

Assessor's declaration The assessor is not related to the owner of the property.

Date of assessment 6 February 2020
Date of certificate 26 February 2020