

# Energy performance certificate (EPC)

5 Cagefield Cottages  
Stambridge Road  
Stambridge  
ROCHFORD  
SS4 2BD

Energy rating

C

Valid until:

23 May 2033

Certificate number:

0300-2834-0250-2027-8785

Property type

Semi-detached house

Total floor area

79 square metres

## Rules on letting this property


Properties can be let if they have an energy rating from A to E.

You can read [guidance for landlords on the regulations and exemptions](https://www.gov.uk/guidance/domestic-private-rented-property-minimum-energy-efficiency-standard-landlord-guidance) (<https://www.gov.uk/guidance/domestic-private-rented-property-minimum-energy-efficiency-standard-landlord-guidance>).

## Energy rating and score

This property’s current energy rating is C. It has the potential to be B.

[See how to improve this property’s energy efficiency.](#)



The graph shows this property’s current and potential energy rating.

**Properties get a rating from A (best) to G (worst) and a score.** The better the rating and score, the lower your energy bills are likely to be.

For properties in England and Wales:

the average energy rating is D  
the average energy score is 60

## Breakdown of property's energy performance

### Features in this property

Features get a rating from very good to very poor, based on how energy efficient they are. Ratings are not based on how well features work or their condition.

Assumed ratings are based on the property's age and type. They are used for features the assessor could not inspect.

| Feature              | Description                                    | Rating    |
|----------------------|------------------------------------------------|-----------|
| Wall                 | Solid brick, as built, no insulation (assumed) | Very poor |
| Wall                 | Cavity wall, as built, no insulation (assumed) | Poor      |
| Wall                 | Cavity wall, as built, insulated (assumed)     | Very good |
| Roof                 | Pitched, 300 mm loft insulation                | Very good |
| Roof                 | Flat, limited insulation                       | Poor      |
| Roof                 | Pitched, insulated (assumed)                   | Good      |
| Window               | Fully double glazed                            | Good      |
| Main heating         | Boiler and radiators, mains gas                | Good      |
| Main heating control | Programmer, room thermostat and TRVs           | Good      |
| Hot water            | From main system                               | Good      |
| Lighting             | Low energy lighting in all fixed outlets       | Very good |
| Floor                | Solid, no insulation (assumed)                 | N/A       |
| Floor                | Solid, insulated (assumed)                     | N/A       |
| Secondary heating    | None                                           | N/A       |

### Primary energy use

The primary energy use for this property per year is 200 kilowatt hours per square metre (kWh/m<sup>2</sup>).

## How this affects your energy bills

An average household would need to spend **£1,439 per year on heating, hot water and lighting** in this property. These costs usually make up the majority of your energy bills.

You could **save £330 per year** if you complete the suggested steps for improving this property's energy rating.

This is **based on average costs in 2023** when this EPC was created. People living at the property may use different amounts of heating, hot water and lighting.

---

### Heating this property

Estimated energy needed in this property is:

- 8,422 kWh per year for heating
- 2,052 kWh per year for hot water

### Saving energy by installing insulation

Energy you could save:

- 456 kWh per year from cavity wall insulation
- 2,436 kWh per year from solid wall insulation

### More ways to save energy

Find ways to save energy in your home by visiting [www.gov.uk/improve-energy-efficiency](https://www.gov.uk/improve-energy-efficiency).

---

## Environmental impact of this property

This property's current environmental impact rating is D. It has the potential to be B.

Properties get a rating from A (best) to G (worst) on how much carbon dioxide (CO<sub>2</sub>) they produce each year. CO<sub>2</sub> harms the environment.

|                               |                             |
|-------------------------------|-----------------------------|
| An average household produces | 6 tonnes of CO <sub>2</sub> |
|-------------------------------|-----------------------------|

|                        |                               |
|------------------------|-------------------------------|
| This property produces | 2.8 tonnes of CO <sub>2</sub> |
|------------------------|-------------------------------|

---

|                                      |                               |
|--------------------------------------|-------------------------------|
| This property's potential production | 1.0 tonnes of CO <sub>2</sub> |
|--------------------------------------|-------------------------------|

---

You could improve this property's CO<sub>2</sub> emissions by making the suggested changes. This will help to protect the environment.

Environmental impact ratings are based on assumptions about average occupancy and energy use. They may not reflect how energy is consumed by the people living at the property.

---

## Changes you could make

| Step                                    | Typical installation cost | Typical yearly saving |
|-----------------------------------------|---------------------------|-----------------------|
| 1. Internal or external wall insulation | £4,000 - £14,000          | £257                  |

---

| Step                         | Typical installation cost | Typical yearly saving |
|------------------------------|---------------------------|-----------------------|
| 2. Solar water heating       | £4,000 - £6,000           | £74                   |
| 3. Solar photovoltaic panels | £3,500 - £5,500           | £745                  |

### Paying for energy improvements

You might be able to get a grant from the [Boiler Upgrade Scheme \(https://www.gov.uk/apply-boiler-upgrade-scheme\)](https://www.gov.uk/apply-boiler-upgrade-scheme). This will help you buy a more efficient, low carbon heating system for this property.

---

## Who to contact about this certificate

### Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

|                 |                                                                          |
|-----------------|--------------------------------------------------------------------------|
| Assessor's name | Ashley Seymour                                                           |
| Telephone       | 07727555382                                                              |
| Email           | <a href="mailto:ashmourservices@gmail.com">ashmourservices@gmail.com</a> |

### Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

|                      |                                                                                    |
|----------------------|------------------------------------------------------------------------------------|
| Accreditation scheme | Elmhurst Energy Systems Ltd                                                        |
| Assessor's ID        | EES/022014                                                                         |
| Telephone            | 01455 883 250                                                                      |
| Email                | <a href="mailto:enquiries@elmhurstenergy.co.uk">enquiries@elmhurstenergy.co.uk</a> |

### About this assessment

|                        |                       |
|------------------------|-----------------------|
| Assessor's declaration | No related party      |
| Date of assessment     | 24 May 2023           |
| Date of certificate    | 24 May 2023           |
| Type of assessment     | <a href="#">RdSAP</a> |

---