

Energy performance certificate (EPC)

BROADFIELD FARM COTTAGE
DENT
SEDBERGH
LA10 5TG

Energy rating

E

Valid until: 28 July 2031

Certificate number: 9309-2349-5002-1923-0902

Property type

Semi-detached house

Total floor area

214 square metres

Rules on letting this property

Properties can be rented if they have an energy rating from A to E.

If the property is rated F or G, it cannot be let, unless an exemption has been registered. You can read [guidance for landlords on the regulations and exemptions \(https://www.gov.uk/guidance/domestic-private-rented-property-minimum-energy-efficiency-standard-landlord-guidance\)](https://www.gov.uk/guidance/domestic-private-rented-property-minimum-energy-efficiency-standard-landlord-guidance).

Energy efficiency rating for this property

This property's current energy rating is E. It has the potential to be B.

[See how to improve this property's energy performance.](#)

Score	Energy rating	Current	Potential
92+	A		
81-91	B		88 B
69-80	C		
55-68	D		
39-54	E	51 E	
21-38	F		
1-20	G		

The graph shows this property's current and potential energy efficiency.

Properties are given a rating from A (most efficient) to G (least efficient).

Properties are also given a score. The higher the number the lower your fuel bills are likely to be.

For properties in England and Wales:

the average energy rating is D
the average energy score is 60

Breakdown of property's energy performance

This section shows the energy performance for features of this property. The assessment does not consider the condition of a feature and how well it is working.

Each feature is assessed as one of the following:

- very good (most efficient)
- good
- average
- poor
- very poor (least efficient)

When the description says "assumed", it means that the feature could not be inspected and an assumption has been made based on the property's age and type.

Feature	Description	Rating
Wall	Sandstone or limestone, as built, no insulation (assumed)	Very poor
Roof	Roof room(s), insulated (assumed)	Good
Roof	Pitched, 150 mm loft insulation	Good
Window	Mostly double glazing	Average
Main heating	Boiler and radiators, oil	Average
Main heating control	Programmer, room thermostat and TRVs	Good
Hot water	From main system, no cylinder thermostat	Poor
Lighting	Low energy lighting in 94% of fixed outlets	Very good
Floor	Solid, no insulation (assumed)	N/A
Secondary heating	Room heaters, dual fuel (mineral and wood)	N/A

Primary energy use

The primary energy use for this property per year is 249 kilowatt hours per square metre (kWh/m²).

Additional information

Additional information about this property:

- Stone walls present, not insulated

Environmental impact of this property

This property's potential production 5.3 tonnes of CO₂

One of the biggest contributors to climate change is carbon dioxide (CO₂). The energy used for heating, lighting and power in our homes produces over a quarter of the UK's CO₂ emissions.

By making the [recommended changes](#), you could reduce this property's CO₂ emissions by 8.6 tonnes per year. This will help to protect the environment.

An average household produces 6 tonnes of CO₂

Environmental impact ratings are based on assumptions about average occupancy and energy use. They may not reflect how energy is consumed by the people living at the property.

This property produces 13.9 tonnes of CO₂

How to improve this property's energy performance

Making any of the recommended changes will improve this property's energy efficiency.

If you make all of the recommended changes, this will improve the property's energy rating and score from E (51) to B (88).

Recommendation	Typical installation cost	Typical yearly saving
1. Internal or external wall insulation	£4,000 - £14,000	£561
2. Floor insulation (solid floor)	£4,000 - £6,000	£80
3. Increase hot water cylinder insulation	£15 - £30	£33
4. Hot water cylinder thermostat	£200 - £400	£92
5. Condensing boiler	£2,200 - £3,000	£99
6. Solar water heating	£4,000 - £6,000	£46
7. Solar photovoltaic panels	£3,500 - £5,500	£335
8. Wind turbine	£15,000 - £25,000	£720

Paying for energy improvements

[Find energy grants and ways to save energy in your home. \(https://www.gov.uk/improve-energy-efficiency\)](https://www.gov.uk/improve-energy-efficiency)

Estimated energy use and potential savings

Estimated yearly energy cost for this property	£2320
--	-------

Potential saving	£911
------------------	------

The estimated cost shows how much the average household would spend in this property for heating, lighting and hot water. It is not based on how energy is used by the people living at the property.

The estimated saving is based on making all of the recommendations in [how to improve this property's energy performance](#).

For advice on how to reduce your energy bills visit [Simple Energy Advice](#) (<https://www.simpleenergyadvice.org.uk/>).

Heating use in this property

Heating a property usually makes up the majority of energy costs.

Estimated energy used to heat this property

Space heating	31759 kWh per year
---------------	--------------------

Water heating	4593 kWh per year
---------------	-------------------

Potential energy savings by installing insulation

Type of insulation	Amount of energy saved
--------------------	------------------------

Loft insulation	337 kWh per year
-----------------	------------------

Solid wall insulation	9643 kWh per year
-----------------------	-------------------

You might be able to receive [Renewable Heat Incentive payments](#) (<https://www.gov.uk/domestic-renewable-heat-incentive>). This will help to reduce carbon emissions by replacing your existing heating system with one that generates renewable heat. The estimated energy required for space and water heating will form the basis of the payments.

Contacting the assessor and accreditation scheme

This EPC was created by a qualified energy assessor.

If you are unhappy about your property's energy assessment or certificate, you can complain to the assessor directly.

If you are still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation schemes are appointed by the government to ensure that assessors are qualified to carry out EPC assessments.

Assessor contact details

Assessor's name	Peter Ryan
Telephone	07968071279
Email	info@epc-cumbria.com

Accreditation scheme contact details

Accreditation scheme	Quidos Limited
Assessor ID	QUID205877
Telephone	01225 667 570
Email	info@quidos.co.uk

Assessment details

Assessor's declaration	No related party
Date of assessment	27 July 2021
Date of certificate	29 July 2021
Type of assessment	RdSAP
