

Energy performance certificate (EPC)

APARTMENT Energy Valid 4
2 13 rating until: **October**
MARKET **C** **2030**
SQUARE
KIRKBY
LONSDALE
LA6 2AN
Certificate
number **9310-
3625-
0000-
2400-
5075**

Property Top-floor maisonette
type

Total floor 41 square metres
area

Rules on letting this property

Properties can be rented if they have an energy rating from A to E.

If the property is rated F or G, it cannot be let, unless an exemption has been registered. You can read


[guidance for landlords on the regulations and exemptions](#)

(<https://www.gov.uk/guidance/domestic-private-rented-property-minimum-energy-efficiency-standard-landlord-guidance>).

Energy efficiency rating for this property

This property's current energy rating is C. It has the potential to be C.

[See how to improve this property's energy performance.](#)



The graph shows this property's current and

potential energy efficiency.

Properties are given a rating from A (most efficient) to G (least efficient).

Properties are also given a score. The higher the number the lower your fuel bills are likely to be.

For properties in England and Wales:

the average energy rating is D
the average energy score is 60



Breakdown of property's energy performance

This section shows the energy performance for features of this property. The assessment does not consider the condition of a feature and how well it is working.

Each feature is assessed as one of the following:

- very good (most efficient)
- good
- average
- poor
- very poor (least efficient)

When the description says “assumed”, it means that the feature could not be inspected and an assumption has been made based on the property's age and type.

Feature	Description	Rating
Walls	Average thermal transmittance 0.39 W/m ² K	Good
Roof	Average thermal transmittance 0.16 W/m ² K	Good
Windows	Multiple glazing throughout	Good
Main heating	Boiler and radiators, mains gas	Good
Main heating control	Programmer, TRVs and bypass	Average
Hot water	From main system	Good
Lighting	Low energy lighting in all fixed outlets	Very good
Floor	(other premises below)	N/A
Secondary heating	None	N/A

Feature	Description	Rating
Air tightness	(not tested)	N/A

Primary energy use

The primary energy use for this property per year is 168 kilowatt hours per square metre (kWh/m²).

Environment: impact of this property

One of the biggest contributors to climate change is carbon dioxide (CO₂). The energy used for heating, lighting and power in our homes produces over a quarter of the UK's CO₂ emissions.

An average household produces 6 tonnes of CO₂

This property produces 1.2 tonnes of CO₂

This property's tonne potential production C

By making the [recommended changes](#), you could reduce this property's CO₂ emissions by 0.0 tonnes per year. This will help to protect the environment.

Environmental impact ratings are based on assumptions about average occupancy and energy use. They may not reflect how energy is

consumed by
the people

living at the
property.

How to improve this property's energy performance

The assessor did not make any
recommendations for this property.

[Simple Energy Advice has guidance on
improving a property's energy use.
\(https://www.simpleenergyadvice.org.uk/\)](https://www.simpleenergyadvice.org.uk/)

Paying for energy improvements

[Find energy grants and ways to save
energy in your home.
\(https://www.gov.uk/improve-energy-
efficiency\)](https://www.gov.uk/improve-energy-efficiency)

Estimated energy use and potential savings

Estimated £337
yearly
energy
cost for
this
property

Potential saving £0

The estimated cost shows how much the average household would spend in this property for heating, lighting and hot water. It is not based on how energy is used by the

people living at the property.

The estimated saving is based on making all of the recommendations in [how to improve this property's energy performance](#).

For advice on how to reduce your energy bills visit [Simple Energy Advice](#) (<https://www.simpleenergyadvice.gov.uk>)

Heating use in this property

Heating a property usually makes up the

majority of energy costs.

Estimated energy used to heat this property

Space heating	2636 kWh per year
---------------	-------------------

Water heating	1531 kWh per year
---------------	-------------------

Potential energy savings by installing insulation

The assessor did not find any opportunities to save energy by installing insulation in this property.

You might be able to receive [Renewable Heat Incentive payments](https://www.gov.uk/renewable-heat-incentive) (<https://www.gov.uk/renewable-heat-incentive>). This will help to reduce carbon emissions by replacing your existing heating system with one that generates renewable heat. The estimated energy required for space and water heating will form the basis of the payments.

Contacting the assessor and accreditation scheme

This EPC was created by a qualified energy assessor.

If you are unhappy about your property's energy assessment or certificate, you can complain to the assessor directly.

If you are still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation schemes are appointed by the government to ensure that assessors are qualified to carry out EPC assessments.

Assessor contact details

Assessor's name	Jonathan Murton
Telephone	01524 548313
Email	jonny@murtonand

Accreditation scheme contact details

Accreditation scheme	Elmhurst Energy Systems Ltd
Assessor ID	EES/009007

Telephone	01455 883 250
Email	enquiries@elmhurst.gov.uk

Assessment details

Assessor's declaration	No related party
------------------------	------------------

Date of assessment	5 October 2020
--------------------	----------------

Date of certificate	5 October 2020
---------------------	----------------

Type of assessment	
--------------------	--

SAP

SAP (Standard Assessment Procedure) is a method used to assess and compare the energy and environmental performance of properties in the UK. It uses detailed information about the property's construction to calculate energy performance.

This type of assessment must be carried out on all new properties built after 1 April 2008 in England and Wales, and 30 September 2008 in Northern Ireland.

