

Energy performance certificate (EPC)

22 Fenkle Street
NEWCASTLE UPON TYNE
NE1 5XN

Energy rating

B

Valid until: **25 June 2034**

Certificate number: **1654-9554-6382-6472-9586**

Property type **Retail/Financial and Professional Services**

Total floor area **87 square metres**

Rules on letting this property


Properties can be let if they have an energy rating from A+ to E.

Energy rating and score

This property's energy rating is B.

Properties get a rating from A+ (best) to G (worst) and a score.

The better the rating and score, the lower your property's carbon emissions are likely to be.



How this property compares to others

Properties similar to this one could have ratings:

If newly built

10 A

If typical of the existing stock

39 B

Breakdown of this property's energy performance

Main heating fuel	Grid Supplied Electricity
Building environment	Air Conditioning
Assessment level	3
Building emission rate (kgCO2/m2 per year)	15.47
Primary energy use (kWh/m2 per year)	167

Recommendation report

Guidance on improving the energy performance of this property can be found in the [recommendation report \(/energy-certificate/7640-5533-4721-6818-9682\)](#).

Who to contact about this certificate

Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name	John Ward
Telephone	07875263672
Email	ward62@btinternet.com

Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme	Elmhurst Energy Systems Ltd
Assessor's ID	EES/007259
Telephone	01455 883 250
Email	enquiries@elmhurstenergy.co.uk

About this assessment

Employer	
Employer address	
Assessor's declaration	The assessor is not related to the owner of the property.
Date of assessment	26 June 2024
Date of certificate	26 June 2024
