Energy performance certificate (EPC)

Davenports
Main Street
GRANGE-OVER-SANDS
LA11 6DP

Energy rating

Valid until: 13 February 2028

Certificate number:

0897-0521-7930-8600-7803

Property type

A1/A2 Retail and Financial/Professional services

Total floor area


131 square metres

Rules on letting this property

Properties can be let if they have an energy rating from A+ to E.

Energy rating and score

This property's energy rating is C.



Properties get a rating from A+ (best) to G (worst) and a score.

The better the rating and score, the lower your property's carbon emissions are likely to be.

How this property compares to others

Properties similar to this one could have ratings:

If newly built

25 A

If typical of the existing stock

74 C

Breakdown of this property's energy performance

Main heating fuel	Natural Gas
Building environment	Heating and Natural Ventilation
Assessment level	3
Building emission rate (kgCO2/m2 per year)	102.81
Primary energy use (kWh/m2 per year)	603

Recommendation report

Guidance on improving the energy performance of this property can be found in the <u>recommendation</u> report (/energy-certificate/0020-7968-0478-1890-5074).

Who to contact about this certificate

Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name	lain Donaldson
Telephone	01539 734183
Email	northwestinspector@mail.com

Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme	Elmhurst Energy Systems Ltd
Assessor's ID	EES/019585
Telephone	01455 883 250
Email	enquiries@elmhurstenergy.co.uk

About this assessment

Employer	North West Inspector
Employer address	13 Holme Houses, Burneside, Kendal, LA9 6RA
Assessor's declaration	The assessor is not related to the owner of the
	property.
Date of assessment	8 February 2018
Date of certificate	14 February 2018
	·