Energy performance certificate (EPC)

Howe Foot Lodge Town End GRASMERE LA22 9SQ Energy rating

Valid until: 14 January 2035

Certificate number:

2953-2681-7136-9387-7465

Property type Hotels


Total floor area 525 square metres

Rules on letting this property

Properties can be let if they have an energy rating from A+ to E.

Energy rating and score

This property's energy rating is C.



Properties get a rating from A+ (best) to G (worst) and a score.

The better the rating and score, the lower your property's carbon emissions are likely to be.

How this property compares to others

Properties similar to this one could have ratings:

If newly built

33 B

If typical of the existing stock

131 F

Breakdown of this property's energy performance

Main heating fuel	Natural Gas
Building environment	Heating and Natural Ventilation
Assessment level	3
Building emission rate (kgCO2/m2 per year)	110.29
Primary energy use (kWh/m2 per year)	634

Recommendation report

Guidance on improving the energy performance of this property can be found in the <u>recommendation report</u> (/energy-certificate/1380-3042-1767-2026-0797).

Who to contact about this certificate

Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name	Alasdair Muir
Telephone	07837598482
Email	info@amuirsurveying.co.uk

Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Elmhurst Energy Systems Ltd
EES/018913
01455 883 250
enquiries@elmhurstenergy.co.uk
A Muir Surveying
Moss Side Cottage, Crook Road, Staveley, Kendal,
Cumbria, LA8 9NG
The assessor is not related to the owner of the property.
14 January 2025
15 January 2025