

# Energy performance certificate (EPC)

|                                       |                           |  |
|---------------------------------------|---------------------------|--|
| 2, Sedbergh Road<br>KENDAL<br>LA9 6AD | Energy rating<br><b>F</b> | Valid until: 10 August 2030                  |
|                                       |                           | Certificate number: 8470-7428-7310-2169-6292 |

|                  |                   |
|------------------|-------------------|
| Property type    | End-terrace house |
| Total floor area | 100 square metres |

## Rules on letting this property

### You may not be able to let this property



This property has an energy rating of F. It cannot be let, unless an exemption has been registered. You can read [guidance for landlords on the regulations and exemptions \(https://www.gov.uk/guidance/domestic-private-rented-property-minimum-energy-efficiency-standard-landlord-guidance\)](https://www.gov.uk/guidance/domestic-private-rented-property-minimum-energy-efficiency-standard-landlord-guidance).

Properties can be let if they have an energy rating from A to E. You could make changes to [improve this property's energy rating](#).

## Energy rating and score

This property's energy rating is F. It has the potential to be B.

[See how to improve this property's energy efficiency.](#)

| Score | Energy rating | Current   | Potential   |
|-------|---------------|---|---|
| 92+   | A             |   |   |
| 81-91 | B             |   |  |
| 69-80 | C             |   |   |
| 55-68 | D             |   |   |
| 39-54 | E             |   |   |
| 21-38 | F             |  |   |
| 1-20  | G             |   |   |

The graph shows this property's current and potential energy rating.

**Properties get a rating from A (best) to G (worst) and a score.** The better the rating and score, the lower your energy bills are likely to be.

For properties in England and Wales:

- the average energy rating is D
- the average energy score is 60

# Breakdown of property’s energy performance

## Features in this property

Features get a rating from very good to very poor, based on how energy efficient they are. Ratings are not based on how well features work or their condition.

Assumed ratings are based on the property's age and type. They are used for features the assessor could not inspect.

| Feature              | Description   | Rating    |
|----------------------|---|-----------|
| Wall                 | Sandstone or limestone, as built, no insulation (assumed) | Very poor |
| Roof                 | Pitched, 250 mm loft insulation                           | Good      |
| Roof                 | Pitched, 50 mm loft insulation                            | Poor      |
| Window               | Some double glazing                                       | Very poor |
| Main heating         | Boiler and radiators, mains gas                           | Good      |
| Main heating control | Programmer, no room thermostat                            | Very poor |
| Hot water            | From main system  | Average   |
| Lighting             | Low energy lighting in 7% of fixed outlets                | Very poor |
| Floor                | Suspended, no insulation (assumed)                        | N/A       |
| Secondary heating    | Room heaters, mains gas                                   | N/A       |

## Primary energy use

The primary energy use for this property per year is 538 kilowatt hours per square metre (kWh/m2).

► [About primary energy use](#)

## Additional information

Additional information about this property:

- Stone walls present, not insulated
- Dwelling may be exposed to wind-driven rain

## How this affects your energy bills

An average household would need to spend **£1,915 per year on heating, hot water and lighting** in this property. These costs usually make up the majority of your energy bills.

You could **save £1,270 per year** if you complete the suggested steps for improving this property’s energy rating.

This is **based on average costs in 2020** when this EPC was created. People living at the property may use different amounts of energy for heating, hot water and lighting.

## Heating this property

Estimated energy needed in this property is:

- 22,564 kWh per year for heating
- 2,769 kWh per year for hot water

## Impact on the environment

This property’s environmental impact rating is F. It has the potential to be B.

Properties get a rating from A (best) to G (worst) on how much carbon dioxide (CO2) they produce each year.

## Carbon emissions

|   |                   |
|---|-------------------|
| <b>An average household produces</b>        | 6 tonnes of CO2   |
| <b>This property produces</b>               | 9.5 tonnes of CO2 |
| <b>This property's potential production</b> | 1.8 tonnes of CO2 |

You could improve this property's CO2 emissions by making the suggested changes. This will help to protect the environment.

These ratings are based on assumptions about average occupancy and energy use. People living at the property may use different amounts of energy.

# Steps you could take to save energy

► [Do I need to follow these steps in order?](#)

## Step 1: Internal or external wall insulation

Typical installation cost £4,000 - £14,000

Typical yearly saving £613

Potential rating after completing step 1

52 E

## Step 2: Floor insulation (suspended floor)

Typical installation cost £800 - £1,200

Typical yearly saving £97

Potential rating after completing steps 1 and 2

56 D

## Step 3: Draught proofing

Typical installation cost £80 - £120

Typical yearly saving £26

Potential rating after completing steps 1 to 3

58 D

## Step 4: Low energy lighting

Typical installation cost £65

Typical yearly saving £59

Potential rating after completing steps 1 to 4

59 D

## Step 5: Heating controls (room thermostat and TRVs)

Typical installation cost £350 - £450

Typical yearly saving £156

Potential rating after completing steps 1 to 5

65 D

## Step 6: Replace boiler with new condensing boiler

Typical installation cost £2,200 - £3,000

Typical yearly saving £190

**Potential rating after completing steps 1 to 6****72 C****Step 7: Solar water heating**

Typical installation cost

£4,000 - £6,000

Typical yearly saving

£39

**Potential rating after completing steps 1 to 7****73 C****Step 8: Double glazed windows**

Replace single glazed windows with low-E double glazed windows

Typical installation cost

£3,300 - £6,500

Typical yearly saving

£88

**Potential rating after completing steps 1 to 8****76 C****Step 9: Solar photovoltaic panels, 2.5 kWp**

Typical installation cost

£3,500 - £5,500

Typical yearly saving

£330

**Potential rating after completing steps 1 to 9****85 B****Advice on making energy saving improvements**[Get detailed recommendations and cost estimates](#)**Help paying for energy saving improvements**

You may be eligible for help with the cost of improvements:

- Insulation: [Great British Insulation Scheme](#)
- Heat pumps and biomass boilers: [Boiler Upgrade Scheme](#)
- Help from your energy supplier: [Energy Company Obligation](#)

**Who to contact about this certificate****Contacting the assessor**

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name

Iain Donaldson

Telephone

01539 734183

Email

[northwestinspector@mail.com](mailto:northwestinspector@mail.com)**Contacting the accreditation scheme**

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

|                             |  |
|-----------------------------|--|
| <b>Accreditation scheme</b> | Elmhurst Energy Systems Ltd  |
| <b>Assessor's ID</b>        | EES/019585   |
| <b>Telephone</b>            | 01455 883 250  |
| <b>Email</b>                | <a href="mailto:enquiries@elmhurstenergy.co.uk">enquiries@elmhurstenergy.co.uk</a> |

## About this assessment

|                               |                         |
|-------------------------------|-------------------------|
| <b>Assessor's declaration</b> | No related party        |
| <b>Date of assessment</b>     | 11 August 2020          |
| <b>Date of certificate</b>    | 11 August 2020          |
| <b>Type of assessment</b>     | ► <a href="#">RdSAP</a> |

## Other certificates for this property

If you are aware of previous certificates for this property and they are not listed here, please contact us at [mhcdg.digital-services@communities.gov.uk](mailto:mhcdg.digital-services@communities.gov.uk) or call our helpdesk on 020 3829 0748 (Monday to Friday, 9am to 5pm).

There are no related certificates for this property.

[Help \(/help\)](#) [Accessibility \(/accessibility-statement\)](#) [Cookies \(/cookies\)](#)

[Give feedback \(https://forms.office.com/e/KX25htGMX5\)](https://forms.office.com/e/KX25htGMX5) [Service performance \(/service-performance\)](#)

### OGI

All content is available under the [Open Government Licence v3.0](#)

(<https://www.nationalarchives.gov.uk/doc/open-government-licence/version/3/>), except where otherwise stated



ght (<https://www.nationalarchives.gov.uk/information-management/re-using-public-sector-information/uk-government-licensing-framework/c>